

ACOUSTIC TEST

PROTECTOR 5mm

Testing environment

Protector 5mm was tested in a bedroom under a 35 oz. commercial carpet over an 8 inch concrete slab.

Results: Protector 5mm obtained an FIIC of 73 and an FSTC of 58 which is clearly one of the highest ratings in the market.

For more information about the test results, you can reach;
Dura Undercushions Ltd. at info@dura-undercushions.com

Assembly

- Commercial carpet 35 oz + Protector 5mm= FIIC 73
- 8 inch concrete slab (bare) = FIIC 54

Test Method

- ASTM E336 + ISO 140