

# ACOUSTIC TEST

## DURACUSHION 6mm

### Testing environment

Duracushion 6mm was tested in a bedroom under a 35 oz. commercial carpet over an 8 inch concrete slab.

Results: Duracushion 6mm obtained an FIIC of 76 and an FSTC of 58 which is clearly one of the highest ratings in the market.

For more information about the test results, you can reach;  
Dura Undercushions Ltd. at [info@dura-undercushions.com](mailto:info@dura-undercushions.com)

### Assembly

- Commercial carpet 35 oz + Duracushion 6mm= FIIC 76
- 8 inch concrete slab (bare) = FIIC 54

### Test Method

- ASTM E336. + ISO 140