

ACOUSTIC TEST

DURALUX 7mm

Testing environment

Duralux 7mm was tested in a bedroom under a 35 oz. commercial carpet over an 8 inch concrete slab.

Results: Duralux 7mm obtained an FIIC of 77 and an FSTC of 58 which is clearly one of the highest ratings in the market.

For more information about the test results, you can reach;
Dura Undercushions Ltd. at info@dura-undercushions.com

Assembly

- Commercial carpet 35 oz + Duralux 7mm= FIIC 77
- 8 inch concrete slab (bare) = FIIC 54

Test Method

- ASTM E336 + ISO 140