

ACOUSTIC TEST

SUPER DURA 10mm

Testing environment

Super Dura 10mm was tested in a bedroom under a 35 oz. commercial carpet over an 8 inch concrete slab.

Results: Super Dura 10mm obtained an FIIC of 78 and an FSTC of 59 which is clearly one of the highest ratings in the market.

For more information about the test results, you can reach;
Dura Undercushions Ltd. at info@dura-undercushions.com

Assembly

- Commercial carpet 35 oz + Super Dura 10mm= FIIC 78
- 8 inch concrete slab (bare) = FIIC 54

Test Method

- ASTM E336 + ISO 140